COMMERCIAL BUSINESS BUILDING AND FIRE SAFETY CHECKLIST

Food Services

Note: Questions regarding these requirements may be directed to:

Jared Johnson, Building Official (435) 734-6618 or Jim Buchanan, Fire Marshal (435) 723-4071

 Has application been made to the Bear River Health Department for required permits? Do lights in food preparation and storage areas have covers to contain broken glass? Do indirect waste drains have air-gaps to prevent cross contamination? Is a hood and duct system in place over all appliances, which produce grease, heat or steam exhaust? Are the filters and duct free of grease accumulation? 	
 3) Do indirect waste drains have air-gaps to prevent cross contamination? 4) Is a hood and duct system in place over all appliances, which produce grease, heat or steam exhaust? 	
4) Is a hood and duct system in place over all appliances, which produce grease, heat or steam exhaust?	
exhaust?	
5) Are the filters and duct free of grease accumulation?	laden
6) Do grease ducts have a sheetrock or other fire barrier around them?	
7) Is the hood and duct system fitted with an automatic fire extinguisher system?	
Does the automatic fire extinguisher system have a current six-month certification tag?	
Does the automatic hood fire extinguisher system have a remote pull station?	
10) Is there a size 40:B,C special fire extinguisher in the kitchen area?	